

# Declaration of Performance



Consort Ltd.  
Units 1-4, Export Drive, Huthwaite,  
Sutton-in-Ashfield, Nottinghamshire, NG17 6AF, UK  
17

DoP No: 20- 31/10/17

Veka Matrix FS Tilt and Slide Door, Glazed with NonSoft Coat, and/or Aluminium spacer bar, Argon filled unit.  
Intended for use in domestic or commercial refurbishment.

Annex ZA.1 of BS EN 14351-1:2006+A2:2016

Watertightness: NPD

Dangerous substances: None

Resistance to wind load: NPD

Load-bearing capacity of safety devices: 350N Pass

Acoustic performance: NPD

Thermal transmittance:  $\leq 3.0 \text{ W/m}^2\text{k}$

Radiation Properties: NPD

Air permeability: NPD

A Factory Production Control (FPC) system is established, documented and maintained in accordance with AVCP System 3 as per Annex ZA.2 of BS EN 14351-1:2006+A2:2016.

Report Number 228 FS 6246810-1-3 Rosenheim IFT EN 14609 for the load bearing capacity of safety devices.

Simon Holt  
Name (Print)

Head of Technical

Signed

31/10/2017