

Declaration of Performance



Consort Ltd.
Units 1-4, Export Drive, Huthwaite,
Sutton-in-Ashfield, Nottinghamshire, NG17 6AF, UK
17

DoP No: 6- 31/10/17

VEKA Matrix FS Internally Glazed Reversible Window, Glazed with NonSoft Coat, and/or Aluminium spacer bar, Argon filled unit.
Intended for use in domestic or commercial refurbishment.

Annex ZA.1 of BS EN 14351-1:2006+A2:2016

Watertightness: NPD

Dangerous substances: None

Resistance to wind load: NPD

Load-bearing capacity of safety devices: Pass, 350N (1)

Acoustic performance: NPD

Thermal transmittance: $\leq 3.0 \text{ W/m}^2\text{k}$

Radiation Properties: NPD

Air permeability: NPD

A Factory Production Control (FPC) system is established, documented and maintained in accordance with AVCP System 3 as per Annex ZA.2 of BS EN 14351-1:2006+A2:2016.

(1) Report No. 181947. Clause 5.3 UKAS accredited test house Warrington apt, Tested to BS 6375-2:2009 for the load bearing capacity of safety devices.

Simon Holt
Name (Print)

Head of Technical

Signed

31/10/2017